

# Oil-Only Contractor Grade Sock/Net Boom #WB520SN - 5" x 20', 2 booms/package



Take control of outdoor spill response with Oil-Only Booms.

- Poly-blend filler repels water while only absorbing oil and other hydrocarbons
- Connectors link booms together to create a containment system big enough to handle almost any spill size
- Provides quick, efficient cleanup to help protect the environment from contaminants; suited for short-term use
- Filler color may vary. Color has no effect on performance. However, if you would prefer all white filler, please see our Premium Boom line under item numbers PREM510 (5" x 10') and PREM810 (8" x 10')

## **WB520SN Specifications**

Dimensions:	ext. dia. 5" x 20' L
Shipping	20" W x 23" L x 20" H
Dimensions:	
Sold as:	2 booms per package
Color:	May vary
Composition:	Poly Blend Filler/Polyester
	Netting/Metal Hardware
<b>Recycled Content:</b>	100% Post-Industrial Recycled Poly
	Blend Filler
Absorbency:	Up to 30 gal. per package
Absorbency per:	Up to 15 gal. per boom
Weight:	22 lbs.
# per Pallet:	20
Incinerable:	Yes
Ship Class:	175

## **Metric Equivalent Specifications**

Dimensions:	ext. dia. 13cm x 6.1m L
Shipping	51cm W x 58cm L x 51cm H
Dimensions:	
Absorbency:	Up to 113.6 L per package
Absorbency per:	Up to 56.8 L per boom
Weight:	10 kg



Online: spilltech.com Phone: 1-800-228-3877 (N.Am.) 1-770-475-3877 (Other) Fax: 1-800-872-3764 (N.Am.) 1-770-410-1812 (Other) Email: sales@spilltech.com

6455 East Johns Crossing, Suite 375 • Johns Creek GA 30097 © 2024 SpillTech Environmental Corporation. All rights reserved.

## **WB520SN Technical Information**

#### Warnings & Restrictions:

Color Variance Notice Color may vary.

#### **Regulations and Compliance:**

40 CFR 263.31 - Transporters, "must clean up any hazardous waste discharge that occurs during transportation...so that the hazardous waste discharge no longer presents a hazard to human health or the environment."

40 CFR 122.26 - Facilities must have a detailed plan in place to prevent illegal discharge of pollutants into waterways.

40 CFR 112.7(c)(1) - Facilities must have "appropriate containment and/or diversionary structures to prevent discharge oil from reaching a navigable water course."

33 CFR 154.1047(c)(2) - Concerning navigation and navigable waters, a facility which handles, stores or transports Group V petroleum oils must identify response plan resources such as containment booms and other methods.

#### **Technical Documents:**

(Available at spilltech.com) Product Data Sheet (PDS) Safety Data Sheet (SDS)





Fax: 1-800-872-3764 (N.Am.) 1-770-410-1812 (Other) Email: sales@spilltech.com